

Our Ref: 14/5160/AT/001



29 July 2016

Mrs Annabelle Wilson
Ancon Building Products
President Way
President Park
S4 7UR

Bucknalls Lane
Watford
Herts WD25 9BA
T +44 (0) 1923 665300
E clientservices@bba.star.co.uk
W www.bbacerfs.co.uk

Dear Mrs Wilson

Re: BBA Certificate 14/5160 (Product Sheet 1, 2 and 3 – TeploTie, Teplo-L-Tie and Teplo BF Wall Ties, respectively) – Ancon Building Products

This letter is to confirm that the Ancon Building Products' wall ties, namely TeploTie, Teplo-L-Tie and Teplo BF ties, subject to BBA Certificate 14/5160, were tested for fire resistance performance, in accordance with BRE Global letter with reference number P100399-1064 dated 07/06/2016.

The test results indicated that Teplo-L-Tie (Product Sheet [PS] 2) and Teplo BF Tie (PS3) are valid for fire resistance periods of up to 120 minutes. For the Teplo Ties (PS1), the initial fire test report (with Client report number 247031, dated 28/01/20019) indicates that they have a fire resistance of 60 minutes. Therefore, for PS2 and PS3 of the BBA Certificate 09/4697, it is translated as per the Building Regulations, Approved Document B – Fire Resistance, Table A2 "Minimum periods of fire resistance" that the wall ties can be used in building heights over 30 m, but subject to structural performance.

Therefore, the update in the fire resistance performance, should be incorporated in the 14/5160 BBA Certificate during its next Reissue.

Yours sincerely,

Simon Wroe
Head of Approvals - Engineering

D +44 (0) 1923 665366
M +44 (0) 7880 387515
E swroe@bba.star.co.uk

Product Approval

Installer Approval

Test Services

Management Systems